

Water Testing Results- Eddyville Charter School
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Result
Rm. 54 Classroom Faucet	20971400001CF-21	2.27 ppb
Rm. 53 Classroom Faucet	20971400002CF-21	8.39 ppb
Rm. 49 Classroom Faucet	20971400003CF-21	2.11 ppb
Rm. 47 Classroom Faucet	20971400004CF-21	12.8 ppb
Rm. 48 Classroom Faucet	20971400005CF-21	ND
Elementary Girl's West Bathroom Faucet	20971400006BF-21	6.69 ppb
Elementary Girl's East Bathroom Faucet	20971400007BF-21	11.1 ppb
Elementary Boy's East Bathroom Faucet	20971400008BF-21	4.03 ppb
Elementary Boy's West Bathroom Faucet	20971400009BF-21	ND
Men's Staff Bathroom Faucet	20971400010BF-21	7.52 ppb
MP Hall Drinking Fountain	20971400011DW-21	ND
Women's Staff Bathroom Faucet	20971400012BF-21	9.37 ppb
Counseling Office Faucet	20971400013SF-21	ND
Rm. 26 Faucet	20971400014NS-21	ND
Rm. 28 Espresso Machine	20971400015OT-21	9.62 ppb
Rm. 26 Bathroom Faucet	20971400016BF-21	ND
Kitchen Faucet-Pot Filler	20971400017KF-21	ND
Kitchen Faucet-Dishes	20971400018KF-21	4.68 ppb
Kitchen Bathroom Faucet	20971400019BF-21	11.1 ppb
Office Bathroom Faucet	20971400020BF-21	5.65 ppb
Lobby Drinking Fountain	20971400021DW-21	13.5 ppb
Rm. 5 South Home Ec. Kitchen Faucet	20971400022KF-21	12.1 ppb
Rm. 5 Center Home Ec. Kitchen Faucet	20971400023KF-21	ND
Rm. 5 North Home Ec. Kitchen Faucet	20971400024KF-21	3.75 ppb
Rm. 5 Utility Sink Faucet	20971400025CF-21	11.2 ppb
Rm. 7 South Faucet	20971400026CF-21	13.0 ppb
Rm. 7 North Faucet	20971400027CF-21	ND
H.S. Boy's Bathroom Faucet	20971400028BF-21	9.32 ppb
H.S. Girl's Bathroom Faucet	20971400-029BF	3.06 ppb
Girl's Locker Room East Bathroom Faucet	20971400030BF-21	10.3 ppb
Girl's Locker Room West Bathroom Faucet	20971400031BF-21	2.88 ppb
Boy's Locker Room East Bathroom Faucet	20971400032BF-21	6.51 ppb
Boy's Locker Room West Bathroom Faucet	20971400033BF-21	3.96 ppb
Elementary Drinking Fountain	20971400034DW-21	ND
Rm. 70 West Classroom Faucet	20971401001CF-21	2.65 ppb
Rm. 70 East Classroom Faucet	20971401002CF-21	5.45 ppb
Rm. 70 End/North Classroom Faucet	20971401003CF-21	5.2 ppb
Rm. 75 East Classroom Faucet	20971401004CF-21	ND
Rm. 75 West Classroom Faucet	20971401005CF-21	4.82 ppb
H.S. Drinking Fountain	20971400035DW-21	ND
Kitchen Hand Washing Faucet	20971400036KF-21	9.67 ppb

ND = Non Detect -Lead level is below the set detection limits if 1ppb



Deciphering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 7/20/2021

WO#: 2107324
 CLIENT: Eddyville Charter School
 Location:
 Project:
 Sample Source:

Received Date: 7/7/2021 3:00:00 PM
 Sampler Name: Dawna McLain
 Matrix: Drinking Water
 Treatment:

Lab ID	Client Sample ID	Collection Date	Analyses					
Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst	
2107324-001	20971400001 CF-21	7/7/2021 6:28:00 AM						
SM 3113 B	15.2	15.0	2.00	*	ppb	7/13/2021 4:00:00 PM	KG	
<i>Rm. 54</i>								
2107324-002	20971400002 CF-21	7/7/2021 6:30:00 AM						
SM 3113 B	8.39	15.0	2.00		ppb	7/13/2021 4:00:00 PM	KG	
2107324-003	20971400003 CF-21	7/7/2021 6:32:00 AM						
SM 3113 B	2.11	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG	
2107324-004	20971400004 CF-21	7/7/2021 6:36:00 AM						
SM 3113 B	12.8	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG	
2107324-005	20971400006 BF-21	7/7/2021 6:40:00 AM						
SM 3113 B	6.69	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG	
2107324-006	20971400007 BF-21	7/7/2021 6:39:00 AM						
SM 3113 B	11.1	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG	
2107324-007	20971400008 BF-21	7/7/2021 6:42:00 AM						
SM 3113 B	4.03	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG	

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Original
Page 3 of 12



Delivering more than just test results

ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 7/20/2021

WO#: 2107324
 CLIENT: Eddyville Charter School
 Location:
 Project:
 Sample Source:

Received Date: 7/7/2021 3:00:00 PM
 Sampler Name: Dawna McLain
 Matrix: Drinking Water
 Treatment:

Lab ID: 2107324-008	Client Sample ID	20971400009 BF-21	Collection Date:	7/7/2021 6:43:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-009	Client Sample ID	20971400010 BF-21	Collection Date:	7/7/2021 7:01:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.52	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-010	Client Sample ID	20971400011 DW-21	Collection Date:	7/7/2021 7:02:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-011	Client Sample ID	20971400012 BF-21	Collection Date:	7/7/2021 7:04:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.37	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-012	Client Sample ID	20971400014 NS-21	Collection Date:	7/6/2021 7:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-013	Client Sample ID	20971400015 DW-21	Collection Date:	7/6/2021 7:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.62	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Lab ID: 2107324-014	Client Sample ID	20971400018 KF-21	Collection Date:	7/7/2021 6:46:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	230	15.0	40.0	*	ppb	7/17/2021 6:10:00 PM	AS

dish faucet

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL	Maximum Contaminant Level	NAR See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL Permit Limit
PQL	Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 7/20/2021

WO#: 2107324
CLIENT: Eddyville Charter School
Location:
Project:
Sample Source:

Received Date: 7/7/2021 3:00:00 PM
Sampler Name: Dawna McLain
Matrix: Drinking Water
Treatment:

Lab ID: 2107324-015	Client Sample ID	20971400019 BF-21	Collection Date:	7/7/2021 6:47:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	64.1	15.0	8.00	*	ppb	7/17/2021 8:10:00 PM	AS

Kitchen bathroom faucet

Lab ID: 2107324-016	Client Sample ID	20971400020 BF-21	Collection Date:	7/7/2021 7:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.65	15.0	2.00		ppb	7/17/2021 8:10:00 PM	AS

Lab ID: 2107324-017	Client Sample ID	20971400021 DW-21	Collection Date:	7/7/2021 7:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.5	15.0	2.00		ppb	7/17/2021 8:10:00 PM	AS

Lab ID: 2107324-018	Client Sample ID	20971400022 KF-21	Collection Date:	7/7/2021 7:17:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.1	15.0	2.00		ppb	7/17/2021 8:10:00 PM	AS

Lab ID: 2107324-019	Client Sample ID	20971400024 KF-21	Collection Date:	7/7/2021 7:17:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.75	15.0	2.00		ppb	7/17/2021 8:10:00 PM	AS

Lab ID: 2107324-020	Client Sample ID	20971400025 CF-21	Collection Date:	7/7/2021 7:18:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	18.2	15.0	2.00	*	ppb	7/14/2021 8:23:00 AM	KG

Rm. 5 utility faucet (North)

Lab ID: 2107324-021	Client Sample ID	20971400026 CF-21	Collection Date:	7/7/2021 7:19:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.0	15.0	2.00		ppb	7/14/2021 8:23:00 AM	KG

Qualifiers:
 * Value exceeds Maximum Contaminant Level (MCL)
 C Value is below Minimum Compound Limit
 H Holding times for preparation or analysis exceeded
 MCL Maximum Contaminant Level
 ND Not Detected at the Reporting Limit
 PQL Practical Quantitation Level or Reporting Limit
 A Accredited by ORELAP
 E Value above quantitation range
 LOD Limit of Detection
 NAR See note in Case Narrative
 PL Permit Limit
 R RPD outside accepted recovery limits

Original
Page 5 of 12



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 7/20/2021

WO#: 2107324
CLIENT: Eddyville Charter School
Location:
Project:
Sample Source:

Received Date: 7/7/2021 3:00:00 PM
Sampler Name: Dawna McLain
Matrix: Drinking Water
Treatment:

Lab ID	Client Sample ID	Collection Date
2107324-022	20971400027 CF-21	7/7/2021 7:19:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	18.8 15.0 2.00 * ppb 7/17/2021 6:10:00 PM AS
	<i>Rm. 7 North</i>	
2107324-023	20971400028 BF-21	7/7/2021 7:21:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	9.32 15.0 2.00 ppb 7/17/2021 6:10:00 PM AS
2107324-024	20971400030 BF-21	7/7/2021 7:23:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	10.3 15.0 2.00 ppb 7/17/2021 6:10:00 PM AS
2107324-025	20971400031 BF-21	7/7/2021 7:23:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	19.4 15.0 2.00 * ppb 7/17/2021 6:10:00 PM AS
	<i>Girls LB BF next</i>	
2107324-026	20971400032 BF-21	7/7/2021 7:24:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	6.51 15.0 2.00 ppb 7/18/2021 12:50:00 PM KG
2107324-027	20971400029 BF-21	7/7/2021 7:21:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	3.06 15.0 2.00 ppb 7/18/2021 12:50:00 PM KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Original
Page 6 of 12



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 8/6/2021

WO#: 2107985
CLIENT: Eddyville Charter School
Location:
Project: Eddyville Charter School 6 YR.
Sample Source:

Received Date: 7/21/2021 2:00:00 PM
Sampler Name: Dawna McLain and Gus Loo
Matrix: Drinking Water
Treatment:

Lab ID	Client Sample ID	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2107985-001	Elm. Drink Fountain							7/21/2021 7:05:00 AM	
Lead	SM 3113 B	ND	15.0	2.00			ppb	8/5/2021 12:11:00 PM	KG
2107985-002	Boys LR - West							7/21/2021 7:10:00 AM	
Lead	SM 3113 B	3.96	15.0	2.00			ppb	8/5/2021 12:11:00 PM	KG
2107985-003	Rm. 70 - West							7/21/2021 7:09:00 AM	
Lead	SM 3113 B	2.65	15.0	2.00			ppb	8/5/2021 12:11:00 PM	KG
2107985-004	Rm. 70 - East							7/21/2021 7:10:00 AM	
Lead	SM 3113 B	5.45	15.0	2.00			ppb	8/5/2021 12:11:00 PM	KG
2107985-005	Rm. 75 - West							7/21/2021 7:15:00 AM	
Lead	SM 3113 B	22.5	15.0	4.00	*		ppb	8/5/2021 12:11:00 PM	KG
2107985-006	Rm. 75 - East							7/21/2021 7:15:00 AM	
Lead	SM 3113 B	16.4	15.0	4.00	*		ppb	8/5/2021 12:11:00 PM	KG
2107985-007	H.S. Drink Fountain							7/21/2021 7:09:00 AM	
Lead	SM 3113 B	ND	15.0	2.00			ppb	8/5/2021 12:11:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 8/6/2021

WO#: 2107985
CLIENT: Eddyville Charter School
Location:
Project: Eddyville Charter School 6 YR.
Sample Source:

Received Date: 7/21/2021 2:00:00 PM
Sampler Name: Dawna McLain and Gus Loo
Matrix: Drinking Water
Treatment:

Lab ID:	Client Sample ID				Collection Date:		
2107985-008	Kitchen Hand Wash				7/21/2021 7:06:00 AM		
Analyses	Method	Result	MCL	PQL	Qual Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.67	15.0	2.00	ppb	8/5/2021 12:11:00 PM	KG

Lab ID:	Client Sample ID				Collection Date:		
2107985-009	Counseling Office				7/21/2021 7:16:00 AM		
Analyses	Method	Result	MCL	PQL	Qual Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00	ppb	8/5/2021 12:11:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Original
Page 4 of 7



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 8/20/2021

WO#: 2108328
CLIENT: Eddyville Charter School
Project:
PWS Number:
Sample Source:

Received Date: 8/6/2021 10:23:00 AM
Sampler Name: Gus Loomis
Matrix: Drinking Water
Sample Type:

Lab ID	Client Sample ID	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lab ID: 2108328-001 Client Sample ID: RM7 North Collection Date: 8/5/2021 8:49:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	8/20/2021 8:55:00 AM	KG
Lab ID: 2108328-002 Client Sample ID: Girls LR BF West Collection Date: 8/5/2021 8:47:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.88	15.0	2.00		ppb	8/20/2021 8:55:00 AM	KG
Lab ID: 2108328-003 Client Sample ID: RM54 Collection Date: 8/5/2021 8:59:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.27	15.0	2.00		ppb	8/20/2021 8:55:00 AM	KG
Lab ID: 2108328-004 Client Sample ID: Kitchen BF Collection Date: 8/5/2021 8:57:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.1	15.0	2.00		ppb	8/20/2021 8:55:00 AM	KG
Lab ID: 2108328-005 Client Sample ID: RM5 Utility Collection Date: 8/5/2021 8:51:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.2	15.0	2.00		ppb	8/10/2021 7:44:00 AM	AS
Lab ID: 2108328-006 Client Sample ID: Kitchen Sprayer South Collection Date: 8/5/2021 8:55:00 AM								
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.68	15.0	2.00		ppb	8/20/2021 8:55:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 8/20/2021

WO#: 2108622
CLIENT: Eddyville Charter School
Location:
Project:
Sample Source:

Received Date: 8/13/2021 9:33:00 AM
Sampler Name: Gus Loomis
Matrix: Drinking Water
Treatment:

Lab ID:	Client Sample ID				Collection Date:		
2108622-001	Rm75 East				8/12/2021 8:28:00 AM		
Analyses	Method	Result	MCL	PQL	Qual Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00	ppb	8/20/2021 8:55:00 AM	KG

Lab ID:	Client Sample ID				Collection Date:		
2108622-002	Rm75 West				8/12/2021 8:29:00 AM		
Analyses	Method	Result	MCL	PQL	Qual Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.82	15.0	2.00	ppb	8/20/2021 8:55:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Original
Page 3 of 6



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 10/1/2021

WO#: 2109949
CLIENT: Eddyville Charter School
Project:
PWS Number:
Sample Source:

Received Date: 9/23/2021 10:11:00 AM
Sampler Name: Jason Brooks
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Rm 70 End/North Faucet			Collection Date: 9/23/2021 6:55:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	0.00520	0.0150	0.00200		PPM	9/29/2021 5:00:00 PM	AS

Lab ID:	Client Sample ID	Rm 5 Center Faucet			Collection Date: 9/23/2021 6:49:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	0.0150	0.00200		PPM	9/29/2021 5:00:00 PM	AS

Lab ID:	Client Sample ID	Kitchen Faucet-Pot Filler			Collection Date: 9/23/2021 6:39:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	0.0150	0.00200		PPM	9/29/2021 5:00:00 PM	AS

Lab ID:	Client Sample ID	Rm 26 Bathroom Faucet			Collection Date: 9/23/2021 6:45:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	0.0150	0.00200		PPM	9/29/2021 5:00:00 PM	AS

Lab ID:	Client Sample ID	Rm 48 Classroom Faucet			Collection Date: 9/23/2021 6:42:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	0.0150	0.00200		PPM	9/29/2021 5:00:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit